

TESTING SERVICES

VLS Liquid Test

Prepared For: Maxon Technologies

Halco Job # 1-180426-01

Date: May 2, 2018



5773 Venice Blvd., Los Angeles, California 90019-5017 Office: 323-933-9431 • FAX: 323-933-2043

Table of Contents

Ι.	Introduction	3
н.	List of Equipment	3
Ш.	Results	3
IV.	Test Data Sheets	4

Maxon Technologies Attn. Lee Greer 5400 W Rosecrans Ave Hawthorne, CA 90250

Re: VLS Liquid Test

I. INTRODUCTION

On April 27, 2018 Chris Lussier of Halco Testing Services performed testing of liquid identified as VLS Industrial Fluid Thick Film. The testing was performed at our facility on <u>5773 Venice Blvd</u>, <u>Los Angeles</u> at ambient room temperature of 75F in accordance with ASTM Standard D-877 using a High Voltage Inc. Oil Dielectric Tester Model DTS-60D-TCD3 test instrument. ASTM D-877 standard is used to determine the dielectric breakdown of insulating liquids used in transformers.

II. LIST OF EQUIPMENT

VLS Dielectric, Anti Corrosion, and Lubricant Oil

III. RESULTS

The results of the tests concluded that the dielectric breakdown of the fluid was found to be 8.92kV.

IV. TEST DATA SHEETS

Attached

11100	1
TESTING SERVICES	

Halco Testing Services 5773 Venice BLvd. Los Angeles, CA 90019 323-933-9431

Miscellaneous Test - Data Entry



Customer	Maxon Technologies			Job # 1-180426-01					
Address	5400 W Rosecrans Ave	Hawthorne	CA	Date	4/30/2018			_	
Owner / User	Halco Shop			Ambient Temp.	75	°F	Humidity		%
Address	5773 Venice Blvd.	Los Angeles	CA	Reference #					
Equip Locations	Halco Warehouse			Device ID					
Test Type	ASTM-D877								
Manufacturer	Ship-2-Shore (VLS)	Туре	Oil	S	erial #	N/A			
Catalog #	N/A	Other	1 Gallon Contai	ner					

<u>Results</u>	Breakdown Value
Test 1	8.9kV
Test 2	9.3kV
Test 3	9.0kV
Test 4	8.8kV
Test 5	8.6kV
Average	8.92kV

Comments				
Deficiencies				
Test Equip. IDs	High Voltage DTS60-D Hi POT	0	Tested By	C.Lussier